



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2101110R1

Socket-outlet for fixed installation

Type designation: 1091

Certificate holder: Elko AS
Sandstuveien 68
0680 Oslo Norway

The product complies with the standard(s): IEC 60884-1:2002+A1+A2
SS 428 08 34:2013+T1

Date of expiry: 13 August, 2026

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:

Henrik Wikström

Date: 06 July, 2022

APPENDIX:

Reference No. SE-S-2101110R1

Technical Data:

Type designation	1091
Rated voltage (V)	250V AC
Rated current (A)	16A
Trademark	ELKO
Test Report	444856, 467284
Product information	Two-pole socket-outlet with side-earthing contacts. Standard Sheet III. Thermoplastic, flush mounting, 2 gang, with shutters and screwless terminals. 60mm fixing distance. IP21

Manufacturing Sites:

Merten GmbH
Fritz-Kotz-Strasse 8
51674 Wiehl Germany

This certificate is based on a certificate with Ref. No. P21225626/A1 issued by Nemko AS according to the Nordic Certification Service agreement.

This certificate replaces previously issued ref. No. SE-S-2101110 dated 13 August 2021.
A new certificate has been issued on account of removing one manufacturing site.

Certification Body:

Intertek Semko AB, Product Certification

Place: Kista - Stockholm

Signed:



Date: 06 July, 2022

Henrik Wikström