

CERTIFICATE FI/41648

Our Ref. HEL-CERT230300492-01



Product Timer for installation purpose

Type CDT3600

Trademark 

Certificate Holder Schneider Electric Industries SAS
35 Rue Joseph Monier, 92500, Rueil-Malmaison, France

Technical information 230 V AC, 16 (1) A, 3600 W, class II, IP20

Other information Independently mounted timer. 5000 cycles (A), 500 cycles (M). 1.A.B.Q (micro-disconnection for relay, full disconnection for switch). Screw terminals for maximum 2,5mm² conductors. -10T35°C. Category D, Material group IIIa. PTI175. Pollution degree 2. Uimp: 4,0kV. OVC III.

The product is certified according to the following standard(s) EN 60730-1:2016 + A1:2019 + A2:2022
EN IEC 60730-2-7:2020

Validity This certificate is valid until 2028-03-28 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Date of issue 2023-03-28

SGS Fimko Ltd

Signature


Joonas Leinonen
Certification Manager



Manufacturer

Schneider Electric Industries SAS
35 Rue Joseph Monier, 92500, Rueil-Malmaison, France

Manufacturing site

Lexel Fabrika SIA
Krustpils 35a, LV-1073, Riga, Latvia

Additional information

The products have certificate no. SE-S-2300257 issued by Intertek Semko AB in accordance with the Nordic Certification Service system.

Loads	Rating
Resistive	230V AC, 16A
Inductive	230V AC, 1A $\cos \varphi = 0,6$
Fluorescent lamp (ballasted)	230V AC, 3A 35 μ F
Motor	230V AC, 500 VA
Halogen (230V)	230V AC, 1000W
LED	230V AC, 100W

As shown in the Test Report(s) No(s): 2206369STO-001