

# CERTIFICATE FI/41274

Our Ref. HEL-CERT211201653-01



**Product** Timer  
**Type** ATC10A  
RS16/T10 V

**Trademark** Schneider Electric ( ATC10A)  
ELKO ( RS16/T10 V)

**Certificate Holder** Schneider Electric Industries SAS  
35 Rue Joseph Monier  
FR-92500, Rueil-Malmaison, France

**Technical information** Supply: 230 V, 50 Hz, Load: 10 A, 230 V AC / 10 A, 24 V DC

**Other information** See page 2 of this Certificate

**The product is certified according to the following standard(s)** EN IEC 60730-2-7:2020  
EN 60730-1:2016 + A1:2019

**Validity** This certificate is valid until 29 December 2026 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

**Date of issue** 29 December 2021

**SGS Fimko Ltd**

**Signature**



Seppo Lautamies  
Project Manager



**Manufacturer** Schneider Electric Industries SAS  
35 Rue Joseph Monier  
FR-92500, Rueil-Malmaison, France

**Manufacturing site** Lexel Fabrika SIA  
Krustpils 35a  
LV-1073, Riga, Latvia

**Directive information** The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) and EMC Directive (2014/30/EU) at the date of issue of the certificate.

**Additional information** Relay: 1E5 micro-disconnection  
Features of automatic action: Type 1  
Construction: For flush mounting  
For use in normal pollution situations  
Resistance to heat and fire: Category D  
Degree of protection: IP44 with protective case type BBV49557  
IP20 without protective case type BBV49557

**As shown in the Test Report(s) No(s):** HELES2110001067-1