



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2200947

Socket-outlet

Type designation:

S-1093

Certificate holder:

Elko AS
Sandstuveien 68
0680 Oslo
Norway

The product complies with the standard(s):

IEC 60884-1:2002+A1+A2
SS 428 08 34:2013+T1

Date of expiry:

01 August, 2027

Additional information in Appendix

Certification Body:

Intertek Semko AB, Product Certification

Place:

Kista - Stockholm

Signed:

Date:

01 August, 2022

Leif Mattsson

APPENDIX:

Reference No. SE-S-2200947

Technical Data:

Type designation S-1093
Rated voltage (V) 250V AC
Rated current (A) 16A
Trademark ELKO
Test Report 467276
Product information Catalogue ID: S 1093 PT PH. Socket outlet for fixed installation. Standard Sheet III. Thermoplastic, flush mounting, 3 gang, with shutters and screw terminals, IP20 or IP21 when mounted in declared surface box.
IP21 for the socket-outlet when installed in declared surface box:
Plus: 2-gang box L3478/L992 (40mm high)
RS: 2-gang box L888/L992 (33mm high),
4-gang box L3542/L3543 (33mm high)

Manufacturing Sites:

AS M ja P Nurst
Ümarmäe tn 3 Kärkla
92414 Hiiumaa
Estonia

This certificate is based on a certificate with Ref. No. P22226275 dated 15-07-2022 issued by Nemko Group according to the Nordic Certification Service agreement.

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:



Date: 01 August, 2022

Leif Mattsson

Intertek