



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2300257

Timer for installation purpose

Type designation: CDT3600

Certificate holder: Schneider Electric Industries SAS
35 rue Joseph Monier
92500 Rueil-Malmaison
FRANCE

The product complies with the standard(s): EN 60730-1:2016+A1+A2
EN IEC 60730-2-7:2020


Date of expiry: 10 March, 2028

EU Directive information: According to the principle of presumption of conformity, this certificate constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU.

Intertek

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm


Signed:  **Date:** 10 March, 2023

Leif Mattsson

APPENDIX:

Reference No. SE-S-2300257

Technical Data:

Type designation CDT3600
Rated voltage (V) 230V AC
Rated current (A) 16(1)A
Class Class II
IP-Class IP20
Trademark 

Test Report 2206369STO-001

Product information Independently mounted timer. 5000 cycles (A), 500 cycles (M). 1.A.B.Q (micro-disconnection for relay, full disconnection for switch). Screw terminals for maximum 2,5mm² conductors. -10T35°C. Category D, Material group IIIa. PTI175. Pollution degree 2. Uimp: 4,0kV. OVC III.

Loads	Rating
Resistive	230V AC, 16A
Inductive	230V AC, 1A $\cos \varphi = 0,6$
Fluorescent lamp (ballasted)	230V AC, 3A 35 μ F
Motor	230V AC, 500 VA
Halogen (230V)	230V AC, 1000W
LED	230V AC, 100W

Manufacturing Sites: SIA Lexel Fabrika
 Krustpils street 35A
 LV-1073 Riga, LATVIA

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EU Declaration of Conformity according to the Low Voltage Directive 2014/35/EU. This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

The instruction for use shall be written in a language acceptable according to the national regulation in the country where the product is to be used.

This certificate replaces previously issued ref. No. 1709741 dated 13 November 2017.
 A new certificate has been issued on account of renewal testing and update of standard.

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:



Leif Mattsson

Date: 10 March, 2023