

CERTIFICATE FI/41443

Our Ref. HEL-CERT220701158-01



Product Socket-outlet
Type S-1093
Trademark ELKO
Certificate Holder Elko AS
Sandstuveien 68, N-0680, Oslo, Norway

Technical information 16 A, 250 V~, Standard Sheet III

Other information Catalogue ID: S 1093 PT PH. Socket outlet for fixed installation.
Thermoplastic, flush mounting, 3 gang, with shutters and screw terminals, IP20 or IP21 when mounted in declared surface box.

The product is certified according to the following standard(s) IEC 60884-1:2002 + A1:2006 + A2:2013
SFS 5610:2015 + A11:2016


Validity This certificate is valid until 2027-07-22 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Date of issue 2022-07-22

SGS Fimko Ltd

Signature


Jonas Leinonen
Certification Manager



Manufacturer

Elko AS
Sandstuveien 68, N-0680, Oslo, Norway

Manufacturing site

AS M & P Nurst
Ümarmäe 3, Kärkla 92414, Hiiumaa, Estonia

Additional information

The products have certificate no. P22226275 issued by Nemko Group in accordance with the Nordic Certification Service system.

This certificate replaces previous certificate FI 30025, dated 2017-08-04, due to renewal of the certificate.

IP21 for the socket-outlet when installed in declared surface box:

- Plus: 2-gang box L3478/L992 (40mm high)
- RS: 2-gang box L888/L992 (33mm high),
4-gang box L3542/L3543 (33mm high)

As shown in the Test Report(s) No(s): 467276