



CERTIFICATE FI/42200

Our Ref. HEL-CERT191200790-04

Product Shuttered socket-outlet
Type L3380 series
L973
Trademark ELKO
Certificate Holder Elko AS
Sandstuveien 68, N-0680, Oslo City, Norway

Technical information 16 A, 250 V~
Other information See page 2

The product is certified according to the following standard(s) IEC 60884-1:2022
SFS 5610:2024

Validity This certificate is valid until 20 December 2029 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.


Date of issue 20 December 2024

SGS Fimko Ltd

Signature



Niklas Rönqvist
Certification Manager



Manufacturer

Elko AS
Sandstuveien 68, N-0680, Oslo City, Norway

Manufacturing site

Merten GmbH
Fritz-Kotz-Strasse 8, 51674, Wiehl, North Rhine-Westphalia, Germany

AS M & P Nurst
Ümarmäe 3, Kärdla 92414, Hiiumaa, Estonia

Additional information

The products have certificate no. P24227984 issued by Nemko Group AS in accordance with the Nordic Certification Service system.

Construction:

L3380: Calalogue ID: RS1013 PT. Socket-outlet for fixed installation. Standard sheet III. Thermoplastics, surface mounting, 1 gang, with shutters and screw terminals. IP20, enclosure complies with IP21.

L3380: Calalogue ID: 1054 UPT. Socket-outlet for fixed installation. Standard sheet III. Thermoplastic/thermosetting, surface mounting, 1 gang, with shutters and screw terminals. With lid, with or without key lock. IP44. For use in cold environment down to -25°C.

L973: Catalogue ID: H1013 PT. Socket-outlet for fixed installation. Standard sheet III. Thermoplastic, surface mounting, 1 gang, with shutters and screwless terminals (Elconnect) L957. With extra internal terminal L701 (screwless) or L3053 (screw). IP20, enclosure complies with IP21.

As shown in the Test Report(s) No(s): REP059098