

# Certificate



Intertek

for European Product Safety

Reference No. 1222464

## Switch for household use

Type designation 14003

Certificate holder **ELKO AS**  
Eyvind Lyches vei 10  
1338 Sandvika  
Norway

The product complies with the standard(s) EN 60669-1:1999 and A1+A2

Date of expiry 5 November 2017

EU Directive information The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed

  
Bo Berglöv

Date 5 November 2012  
Page 1 of 2

**Intertek  
Appendix**

Reference No. 1222464

*Technical data*

Type designation 14003  
Rated voltage (V) 400V AC  
Pattern No. 3  
Brand name: 

*Product information*

10 AX. Model RS16/3 I. Flush type. Thermoplastic, screw terminals, with or without claw fixing, with or without pilot lamp. IP20, IP44 when single or double IP44 set is used. RS design, all colours.

Type designation 14003  
Rated voltage (V) 400V AC  
Pattern No. 3  
Brand name: 

*Product information*

10 AX. Model RS16/3 P. Surface type. Thermoplastic, with or without pilot lamp. IP20, IP21 when screen type L3112 is used, screw terminals. RS design, all colours.

Manufacturing site(s) Elko AS  
Sporpind Industriområde  
3340 Åmot  
Norway

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 2006/95/EC.

This certificate is based on a certificate with ref. No. P12216034 dated 18 October 2012, issued by Nemko according to the Nordic Certification Service Agreement.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed   
Bo Berglöv Date 5 November 2012

*This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.*