



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2100756

Socket-outlet with earthing contact

Type designation: 23522, 23523

Certificate holder: Schneider Electric Industries SAS
35 rue Joseph Monier,
92500, Rueil-Malmaison, France

The product complies with the standard(s): IEC 60884-1:2002+A1+A2
SS 428 08 34:2013+T1

Date of expiry: 30 September, 2025

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:  **Date:** 27 May, 2021

Leif Mattsson

APPENDIX:

Reference No. SE-S-2100756

Technical Data:


Type designation 23522, 23523

Rated voltage (V) 250 V~

Rated current (A) 16A

IP-Class IP44

Trademark



Test Report 300162-1

Product information Standard sheet CEE7/III

With possibility to install on wire-rope, 3-phase through 400 V, 2,5 mm².

23522 – with one single socket-outlet S20

23523 – with one double socket-outlet S30

Manufacturing Sites:

AS M&P Nurst
Ümarmäe 3 Kärdda
92414 Hiiumaa Estonia

This certificate is based on a certificate with Ref. No. FI/40839 dated 30 September 2025 issued by SGS Fimko Ltd according to the Nordic Certification Service agreement.

Certification Body: Intertek Semko AB, Product Certification

Place: Kista - Stockholm

Signed:



Date: 27 May, 2021

Leif Mattsson

Intertek